



Centrum för Idrott och Kultur

# Passive Houses and CO<sub>2</sub> – A good combination!



INTRESSEGRUPP   
PASSIVHUS





Sporthalls, officies, restaurant, locker rooms, theatre, ice hall and more:

Demands:

Ice in the icehall

Hot water for making ice, melting snow, showers etc

Ventilation

Heating

Cooling

# CO<sub>2</sub>-UNIT




 **TESAB**  
LABKYL



## Operating mode:

Autumn, Mild winter and Spring


Outdoor temperatur about -2°C and  
above





INTRESSEGRUPP   
PASSIVHUS

# Autumn, Mild winter and spring Cooling the icehall – producing heat and hot water



ENERWEX 



**CO<sub>2</sub>- unit:**  
**Free cooling, Icehall, Heat recovery, Geothermal heating**

Operation mode:


Winter: -3-4°C and colder



# Cold Winter

## Cooling the icehall and working as a ground heat-pump

### Producing heat and hot water





CO<sub>2</sub>- unit:

Free cooling, Icehall, Heat recovery, Geothermal heating

Operation mode:

Summer: Free cooling






INTRESSEGRUPP   
PASSIVHUS

# Summer

## Cooling the icehall – producing heat and hot water

## Cooling the building by Passive cooling



ENERWEX 




# Operation mode:

Summer:

Free cooling with active  
cooling using the CO<sub>2</sub>-unit



Summer – very hot or high activities in the building  
Cooling the icehall – producing heat and hot water  
Cooling the building by Passive- and active cooling









ETAPP 1

# Heat recovery

## Active cooling

## Free cooling

# Bore holes



# CO<sub>2</sub> as a refrigerant

**CO<sub>2</sub> =**

**Natural, compared with other medias as R134a, R407c etc – low impact on the environment.**

**CO<sub>2</sub> – heat recovery: +60 -80°C.**

*Others – heat recovery: +42 -45°C*

**Energy effective**

**Warm heatrecovery.**

**Same technical system as in most normal groceries, well known.**

**Low operating costs.**





# Result PHPP with the icehall

## Resultat PHPP CIK med ishall

Kriterium	Krav	Resultat	Uppfyllda?
Årsvärmebehov (uppvärmning)	15 kWh/(m <sup>2</sup> år)	12,9 kWh/(m <sup>2</sup> år)	Ja
Värmeeffektbehov	10 W/m <sup>2</sup>	12,6 W/m <sup>2</sup>	Nej
Kylbehov	15 kWh/(m <sup>2</sup> år)	3,4 kWh/(m <sup>2</sup> år)	Ja
Övertemperaturfrekvens (>25°C)	< 10%	-	
PER-behov, totalt	115 kWh/(m <sup>2</sup> år)	61 kWh/(m <sup>2</sup> år)	Ja

<sup>\*)</sup> Med genomförda åtgärder som t.ex. sommarventilation

## Resultat BBR CIK med ishall

Krav för byggnaden:

Köpt Energi: 65,0 kWh/(m<sup>2</sup>år)  
U<sub>m</sub>: 0.6 W/(m<sup>2</sup>K)

Resultat:

Köpt Energi: 18,8 kWh/(m<sup>2</sup>år)  
U<sub>m</sub>: 0.17 W/(m<sup>2</sup>K)



Byggnaden uppfyller energikraven.  
Byggnaden uppfyller kraven på värmeisolering.

# Heat demands and gains

## *Heating load for CIK, -16°C outdoor:*

Transmission	90 kW
Ventilation 50% airflow	140 kW
Hot water production	40 kW

## *Heating load CIK, 0°C outdoor:*

Transmission	57 kW
Ventilation 50% airflow	70 kW
Hot water production	40 kW

## *Indoor + 8 °C*

### *Internal heatgains:*

Light 80% usage	(94 kW)
People 30% present	(30 kW)

## *Heat recovery from icehall*

55 kW  
*(after reheating the icehall)*



# Daytime operation - CLK (the whole building, 12 300 m<sup>2</sup>), icehall in use:

## Heat demand, -16°C outdoor temp.

Transmission	-34 kW (Excess)
Ventilation 50% airflow	140 kW
Hot water production	40 kW

## CO<sub>2</sub> heatprod.demand

90 kW more than heat recovery produces.

COP 2,4 = about 37 kW electricity effect bought.

Cooling the ice and working as a ground heat-pump.


## Heat demand, 0°C outdoor temp.

Transmission	-68 kW (Excess)
Ventilation 50% airflow	70 kW
Hot water production	40 kW


## CO<sub>2</sub> heatprod.demand

0 kW more than heat recovery.

The heat recovery and internal gains covers the demand.



# Temperatures in Knivsta 2012 - 2019



Heat demand covered by  
normal ice-hall operation

Ice-hall + bore holes








**Normally, the heat recovery from an icehall doesn't even cover the heat demand of the icehall it self....**





INTRESSEGRUPP   
PASSIVHUS



**... but with a Passive House as a base, a ground collector (renewable energy) and, on top, an active CO<sub>2</sub>-unit, installed for the activities in the icehall – we...**





INTRESSEGRUPP   
PASSIVHUS



... cover every comfort- and energy demand in the whole building!

